

Designated Drinking Sources Over 5ppb  
Samples Taken 1/26/24

**Early Childhood Center**

None

**Esther**

LE-43 (bottle filler) 5.3 ug/L

**Maplecrest**

LM-77 Bubblers 23.0 ug/L

LM-79 Bubblers 7.3 ug/L

**Boswell**

LB-60 (bubbler) 6.4 ug/L

LB-94 (bubbler) 5 ug/L

LB-96 (bubbler) 8.6 ug/L

**Middle School**

None

**High School**

LHS-31 (bubbler) 11 ug/L

LHS-33 (bubbler) 16 ug/L

LHS-37 (bubbler) 13 ug/L

LHS-39 (bubbler) 15 ug/L

LHS-61 (bubbler) 19 ug/L

LHS-63 (bubbler) 10 ug/L

LHS-69 (bubbler) 12 ug/L

LHS-71 (water fountain) 8.5 ug/L

LHS-140 (water fountain) 5.2 ug/L

LHS-144 (water fountain) 8.1 ug/L

**LTCC**

LTCC-17 (water fountain) 5.3 ug/L

**Hillcrest**

LHEC-49 (bubbler) 17 ug/L

**Field House**

None

**Maintenance/Transportation**

None